



RAJKOT MUNICIPAL CORPORATION



Dr. Ambedkar Bhavan, Dhebar Road
Fire & Emergency Service
Rajkot - 360 001.

RMC.F.B.NOC.NO.1192.

Date:-05.02.2022.

-:: FIRE NO OBJECTION CERTIFICATE ::-

Reference No.1.R.M.C.F.E.S.NOC.E.No.1203, DATE:-14-10-2020.

This is to School Building Fire N.O.C Mr. Milind Kaluskar (Principal) "DELHI WORLD PUBLIC SCHOOL", Type of Building:-Frame Structure, Use of Building :-Educational, Rev.Sr.No.300P/1, Location :- Village :- Virpar, B/H Baa Ni Vadi, Morbi Rajkot Highway, Morbi, Area Table :- Plot Area = 29036 sq ft. School Building Floor :-G.F.+3rd Floor, Total Built Up Area = 41773 sq ft. Have Complied With Fire Act / BPMC ACT 1949 Building Law & NBC 1984 To 2019 RMC and Verified by Fire officer of Fire and emergency services RMC Rajkot on Dated 31-01-2020.


- (1) Fire Hydrant System, Fire Hose Reel Hose, Fire extinguisher & Fire Safety Equipments in Building Area Both Side Lobby Area ABC Type fire extinguisher Capacity 5/6 k.g & Co2 Type fire extinguisher 4.5 k.g & 5/6 k.g DCP Type fire extinguisher Fire Station Officer Guideline Building in Area.
- (2) However the following terms & Condition shall be complied with time and reports shall be submitted to concerned authority.
- (3) The School Staff and students shall have to undergo fire prevention Training once in a yearly By School Fire Service Fire Officials and Record there of shall be Maintained.
- (4) Electric Wiring must be proper and that Not be Loose and Taped in Room.
- (5) There should not be any Obstacle in Exit and Emergency lights in Stares & Exit Marked by Radium Symbol is Necessary.
- (6) Fire fighting in underground / overhead Fire water tank in Area.
- (7) Emergency Services Like Fire, Medical, Police, Health director Telephone Numbers should be list out put on hand in security entry point and office room.
- (8) These Fire Hydrant System, Fire extinguisher & Fire Safety Equipments shall be maintained in working order in the valid period this Corticated.
- (9) Above must be followed as per Fire Hydrant System, Fire extinguisher & Fire Safety Equipments Act/Rules.
- (10) This Fire N.O.C is Valid Up to Date 05 February 2023 Then after it should be Next Time Renew Again inspection Fire Department.

Place :-Rajkot.

Date :-05-02-2022.


PRINCIPAL
DELHI WORLD PUBLIC SCHOOL
MORBI




I/C Chief Fire Officer
Fire & Emergency Services
Rajkot Municipal Corporation


MANAGER
DELHI WORLD PUBLIC SCHOOL
MORBI